

Volney Volunteer Fire Corporation

3002 State Rt.3
Fulton, NY 13069
315-593-7473



Fireworks Display Checklist

Responsible Person: _____

Name of Contact on-site: _____ Phone # of Contractor: _____

When the Volney Fire Corp. is sponsoring a Fireworks Display, this checklist will be used to help The Volney Fire Corp. address the hazards and exposures associated with the display.

- Professional Fireworks Company contracted to fire the shells.
- Responsibility for clean-up clearly defined in contract with professional fireworks company and is the responsibility of professional fireworks company.
- Certificate of Insurance obtained from Fireworks Company with minimum limits of 1,000,000 for bodily injury and property damage.
- Volney Fire Corp. named as additional insured on contractors certificate of insurance.

Display Area (Also see NFPA # 1123)

- Display area adequate for size of aerial shell.
- 70 foot radius for every inch of internal mortar diameter.
- No spectators, dwellings or parking areas within display area.

Discharge Area (Also see NFPA # 1123)

- Distance from discharge area to spectators is adequate.
- Security to discharge area is adequate.
- At least 25 foot clearance to any overhead objects for shell trajectory.
- At least 75 foot clearance between spectator viewing areas or parking areas and ground display pieces.
- Storage of shells at discharge site is adequate.

Fall-Out Area (Also see NFPA #1123)

- No spectators, vehicles or combustible materials located within fall-out areas.

Volney Fire Corporation

- Adequate fire protection, fire apparatus and emergency medical service provided during display.
- Adequate monitors provided to enforce crowd control and observe falling of live debris.
- Adequate communication capabilities between monitors and fire apparatus.

Clean-up

- Display area not open to public until daylight clean-up completed.
- Daylight clean-up completed.
- Procedures in place for handling unexploded shells.

National Fire Protection Association (NFPA) #1123 provides more information on how to properly conduct a fireworks display. Please review those requirements before holding our event.

NFPA
1 Batterymarch Park
Quincy, MA 02269-9101
(617)770-3000

Pyrotechnics Guild International, Inc. is another source for information about fireworks displays. For more information on them please contact:

Ed Vanasek
18021 Baseline
Jordon, MN 55352
(612)492-2061